

July 28, 2023

Marc Thorne, Mayor  
Town of Sussex  
524 Main St  
Sussex, NB  
E4E 3E4

**RE: INTERDICTION – Village of Sussex Corner, Sussex Corner NB**

Your Worship,

On July 21, 2023, the Village of Sussex Corner issued a boil water advisory due to the presence of total coliforms in the distribution system.

Therefore, under Section 6(2) of the New Brunswick *Public Health Act*, the order issued on July 21, 2023 is rescinded and this order is in effect. The boil order will remain in effect until the following actions have been completed:

A submission of a remediation plan to the Regional Medical Officer of Health for approval prior to implementation. The plan must include the following:

- A full description of your treatment train and functioning of your drinking water infrastructure including but not limited to the operational components, the types of alarms, continuous on-line monitoring equipment, etc.
- A proposal and installation of continuous on-line monitoring equipment for critical health related parameters such as free chlorine and turbidity.
- Immediate reporting of any parameter that exceeds a health-related parameter, including if turbidity exceeds 1 NTU.
- The messaging issued to the public for the issuance and persistence for the duration of the boil order must be approved by the Regional Medical Officer of Health.

Following completion of all of the above-mentioned conditions and stabilization of all operational parameters, 2 consecutive sets of acceptable bacteriological water samples from all distribution system sites collected a minimum of 16 hours apart are required prior to rescinding the order.

---

**Department of Health**

Office of the Chief Medical Officer of Health  
South Region  
55 Union Street, P.O. Box 93, Saint John, NB E2L 3X1  
Telephone: (506) 658-3022 FAX: (506) 643-7894  
Toll-free number: 1-888-652-1333

---

**Ministère de la santé**

Bureau du médecin-hygiéniste en chef  
Région sud  
55, rue Union, C.P. 93, Saint John, NB E2L 3X1  
Accueil: (506) 658-3022 Telecopieur: (506) 643-789  
Numéro sans frais: 1-888-652-1333

If you have any questions, please contact your local Health Protection Services office at (506) 658-3022.

Sincerely,



Dr. Kimberly Barker  
Medical Officer of Health, South Region

Cc: Shaun Crawley, Regional Director, South Region  
Christopher Biggs, Clean Water Act Coordinator, South Region