

## Sussex Water Source of Supply

Sussex draws its potable (drinkable) water from an underground, unconfined aquifer supplied by two deep wells located within the municipality. The pumping stations are capable of a maximum combined flow rate of 5.7 cubic meters/minutes (1,250 Imperial gallons/minute) into the distribution system. Reservoirs with a combined capacity of 5,428,000 litres provide backup supply.

The Town of Sussex chlorinates its potable water at the well heads by means of constant automated chlorination to maintain a safe residual level at all times. The rate of chlorine integration is approximately 0.8mg/L (ppm).

### Related Links

For those who wish to explore water and wastewater issues, the following Internet addresses may be helpful:


American Water Works Association  
[www.awwa.org](http://www.awwa.org)

Environment Canada  
<https://www.ec.gc.ca/eau-water/>

Water Environment Federation  
[www.wef.org](http://www.wef.org)

GNB Water Classification Regulation  
[www.gnb.ca](http://www.gnb.ca)

## Did you know?



75% of all water use is in the bathroom! Little changes like taking shorter showers, flushing less often and turning the water off while brushing your teeth have a huge impact on our environment.

- ⌚ Take a trip to the car wash instead of

### Tips to conserve water at home

washing your car at home.


- ⌚ Use a dish of water to wash vegetables instead of running the water continuously.
- ⌚ Only water your lawn during early morning hours when there is less lost to wind and evaporation.

Try to do one small thing each day, it will become a habit in no time!

A continuous leak through a hole this small wastes **74,000 gallons** of water in just three months!

### Water Leaks

*If you hear noises in pipes in your home or property, that you suspect might be caused by water leakage, give us a call! We will be happy to help determine the cause and remedy.*



## 2017 Annual Water Quality Testing Results

524 Main Street  
Sussex, NB  
E4E 3E4

(506) 432-4540  
[www.sussex.ca](http://www.sussex.ca)

# WATER QUALITY INORGANIC (CHEMICAL) TESTING RESULTS 2017

Chemical Parameters		Canadian Drinking Water Quality Guideline	Average of Results	Range of Detection
<b>Inorganic Parameters</b> -naturally occurring or synthetic substances containing carbon, hydrogen, nitrogen, and oxygen.				
<b>Alkalinity</b> -capacity of water to neutralize acids	mg/L	-	106.3	105-109
<b>Aluminum</b> -inorganic element	ug/L	100	<5	<5
<b>Antimony</b> -element used in metal manufacturing	mg/L	6	<2	<2
<b>Arsenic</b> -can be naturally occurring or from industrial effluents	ug/L	10	<1	<1
<b>Barium</b> -found in naturally occurring compounds and industrial processes	ug/L	1000	84.7	72-92
<b>Boron</b> -naturally occurring in over 80 minerals and within the earth's crust	mg/L	5	<0.1	<0.1
<b>Cadmium</b> -present as an impurity in galvanized pipe, also present in solder	ug/L	5	<0.2	<0.2
<b>Calcium</b> -related to hardness	mg/L	-	46.3	38.8-54.5
<b>Chloride</b> -natural element, found in salt used for ice control and in chemical industry effluents	mg/L	250	14.8	14.6-15.1
<b>Chromium</b> -naturally occurring metallic ion	ug/L	50	<1	<1
<b>Conductivity</b> -measure of the ability of water to carry electric current	uS/cm	-	319.3	305-345
<b>Copper</b> -can cause staining in laundry above Health Advisory Limit	ug/L	1000	3	<1-3
<b>Fluoride</b> -naturally occurring in minerals and soils	mg/L	1.5	<0.1	<0.1
<b>Iron</b> -natural metallic ion, can cause laundry and plumbing fixture staining	ug/L	300	3	<2-6
<b>Lead</b> -common element, found in older plumbing installations, also can be present in solder	ug/L	10	<1	<1
<b>Magnesium</b> -contributed to water hardness	mg/L	-	3.8	3.6-4.2
<b>Manganese</b> -natural metallic ion, can cause laundry and plumbing fixture staining	ug/L	50	<2	<2
<b>Mercury</b> -a heavy crystalline salt	ug/L	1	<0.2	<0.2
<b>Nitrate-nitrite</b> -naturally occurring ion, used in inorganic fertilizers	mg/L	-	0.9	0.7-1.3
<b>pH</b> -measure of acidity or causticity	ug/L	6.5-8.5	7.25	7.15-7.35
<b>Potassium</b> -second most abundant element in the earth's crust	mg/L	-	0.4	0.1-0.8
<b>Selenium</b> -inorganic element	ug/L	10	<2	<2
<b>Sodium</b> -most abundant element in the earth's crust, high concentrations can affect taste	mg/L	200	9.0	7.90-9.70
<b>Sulfate</b> -naturally occurring in numerous minerals.	mg/L	500	24.7	20-33
<b>Thallium</b> -rare natural metallic element	ug/L	-	<1	<1
<b>Total Hardness</b> -caused by dissolved natural salts	Ca/Mg	-	131.7	112-154
<b>Turbidity</b> -measurement of suspended material in the water	NTU	-	0.1	0.12-0.15
<b>Uranium</b> -found in certain rare minerals	ug/L	20	0.7	<0.5-0.8
<b>Zinc</b> -can be found in some plumbing fixtures	ug/L	500	7	<2-12

UNITS = mg/l are parts per million and ug/l are parts per billion

## WATER SAMPLING & TESTING

### CHEMICAL ANALYSIS (INORGANIC)

Town of Sussex water comes from two municipal wells. As the water travels through the ground, it dissolves naturally occurring minerals.

In order to ensure that Sussex water is safe to drink, a number of chemical analyses are performed each year. The results from the most recent analysis are presented in this report. The Average of Results indicates the average of the **three** locations tested. The Range of Detections indicates the lowest detections to the highest in each parameter.

### ORGANIC ANALYSIS

Two Town wells and a third location are sampled for Clean Water Act parameters twice a year.

### BACTERIOLOGICAL ANALYSIS

Ten sites are sampled weekly for bacteriological parameters.

### CHLORINE ANALYSIS

Twelve sites are sampled twice weekly for chlorine content. Of these twelve sites, four sites are sampled on each working day. These include the well sites.